

1 10A NCAC 14E .0209 is proposed for adoption under temporary procedures as follows:

2
3 **10A NCAC 14E .0209 ELEVATOR**

4 (a) In multi-story buildings, at least one elevator for patient use shall be provided.

5 (b) At least one dimension of the elevator cab shall be six and one-half feet to accommodate stretcher patients.

6 (c) The elevator door shall have an opening of no less than three feet in width, which is minimum for stretcher use.

7
8 History Note: Authority G.S. 143B-10; S.L. 2023-14, s. 2.4;